



**TEST REPORT**

Job No : 7264-313011

Report No : BRD/7264-313011-RMP/3130022

Sample No : 3130022

Report Date : 11-03-2026

Client : IKYA Building Solutions LLP.

Contractor : -

Consultant : -

Name of Work : Testing of Readymix Plaster.

Reference No. : Mail Letter Dated:-07-02-2026

Type of Cement : Ready Mix Plaster

Sample Size (Kg) : 15

Manufacturer Name : -

Sample submitted by : Client

Batch No. : -

Date of Test Started : 11-02-2026

Date of Sample Rece. : 09-02-2026

Date of Test Completed : 11-03-2026

Item No.	Test Name	Unit	Test Result
1	Water Powder Ratio	%	0.22
2	Compressive Strength		
a) 3 Days		N/mm <sup>2</sup>	6.06
b) 7 Days			10.08
c) 28 Days			16.18

Tested by : VK

Reference Standard : IS 4031 (Part-5)-1988



**NOTE:**

1. This certificate or report may not be published for commercial purpose except in full unless permission for the publication of an approved abstract has been obtained from the GEO TEST HOUSE, Vadodra.
2. This test certificate applies only to the samples received in the laboratory.

*Authorized Signatory*